

North Point North H.D.



Certificate of Appropriateness

LIVING WITH HISTORY

Milwaukee Historic Preservation Commission/809 N. Broadway/PO Box 324/Milwaukee, WI 53201-0324/414-286-5212


Property 2723 E. BRADFORD AV.
Description of work Replace sidewall shingles as needed.
Date issued 8/3/2007 PTS ID 6971 COA - Sidewall Shingles

In accordance with the provisions of Section 308-81(9) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

All work must be done in a craftsman like manner. Repair/replace sidewall shingles as needed with genuine wood shingles not shakes. Any changes must be approved by HPC staff. All finish wood must be smooth and free from knots and sapwood. Staff suggests wood be free of knots, sap wood, 1/4 sawn and of a naturally decay resistant variety.

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Paul Jakubovich of the Historic Preservation staff as follows: Phone: (414) 286-5712 Fax: (414) 286-0232 E-mail: pjakub@milwaukee.gov.

If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, www.mkedcd.org/build, or call (414) 286-8210.



City of Milwaukee/Historic Preservation Staff

Copies to: Development Center, Ald. Michael D'Amato, Inspector